


**Chameleon Flooring - ELSA "REGISTERED FINISH" VINYL FLOORING - 1227X187**

30 Mar 2017

**Slip Resistance Classification of New Pedestrian Surfaces - AS4586:2013 Appendix A**

Date Tested:	30 Mar 2017
Test Report Number:	BO300317-3
Client Name & Address:	Chameleon Flooring - PO BOX 4126 LOGANHOLME DC QLD 4129
Location of Test :	Sliptest Laboratory Gaven
Surface / Product Tested :	ELSA "REGISTERED FINISH" VINYL FLOORING - 1227X187 BN#88066
Wet Pendulum Test carried out using :	Slider 96 (4S) Rubber slider
Record ambient temperature (°C)	27
Testing Officer :	Blair Ording - Munro Portable Skid Tester #0604 - 19.01.16
Testing Officer Signature	

**Test Results :**

	Grade Degrees	Swing 1	Swing 2	Swing 3	Swing 4	Swing 5	Mean BPN of last 3 swings :
Plank 1	< 1.5	41	41	40	40	40	40
Plank 2	< 1.5	44	44	43	43	43	43
Plank 3	< 1.5	40	40	40	40	40	40
Plank 4	< 1.5	45	44	42	42	42	42
Plank 5	< 1.5	43	43	43	43	43	43

Mean BPN Slip Resistance Value (SRV) 42

CLASSIFICATION using Slider 96 (4S Slider) P3 = 35 - 44

Accredited for Compliance with ISO/IEC 17025. The information presented herein and on the Sliptest Report is copyright and is protected by copyright law, any reproduction of this information and test report except in full is prohibited.

Sliptest Australia Pty. Ltd. performed this on site test with reference to the following Australian Standard testing criteria, of AS 4586:2013 Classification of new pedestrian surface materials. Appendix A – Wet Pendulum Test Method and Hand Book HB 198: 2014 with reference to AS/NZS 4663: 2004 Slip Resistance measurement of existing pedestrian surfaces and HB 197: 1999. These results to not account for Future Wear, Maintenance or Contamination of this surface once in-situ.